

51644	2-[N-methylperfluorooctanesulfonamido] acetic acid	1 - Effluent Gross	0	--	Sample	<	4.9	<	4.9	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52602	Perfluorobutanesulfonic acid	1 - Effluent Gross	0	--	Sample	=	8.1	=	8.1	3M - ng/L	01/30 - Monthly	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52603	Perfluorodecanesulfonic acid	1 - Effluent Gross	0	--	Sample	<	2.0	<	2.0	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52604	Perfluoroheptanesulfonic acid	1 - Effluent Gross	0	--	Sample	<	2.0	<	2.0	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52605	Perfluorohexanesulfonic acid	1 - Effluent Gross	0	--	Sample	=	3.9	=	4.0	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52606	Perfluorooctanesulfonic acid	1 - Effluent Gross	0	--	Sample	=	4.0	=	4.1	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52607	4:2 Fluorotelomer sulfonic acid	1 - Effluent Gross	0	--	Sample	<	2.0	<	2.0	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52608	6:2 Fluorotelomer sulfonic acid	1 - Effluent Gross	0	--	Sample	=	0.4	=	0.8	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52609	8:2 Fluorotelomer sulfonic acid	1 - Effluent Gross	0	--	Sample	<	2.0	<	2.0	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52610	Perfluoropentane sulfonic acid	1 - Effluent Gross	0	--	Sample	<	2.0	<	2.0	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52611	Perfluorononane sulfonic acid	1 - Effluent Gross	0	--	Sample	<	2.0	<	2.0	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
52612	Hexafluoropropylene oxide dimer acid	1 - Effluent Gross	0	--	Sample	<	3.9	<	3.9	3M - ng/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	GR - GRAB
					Value NODI							
87006	PFAS Sum	1 - Effluent Gross	0	--	Sample	=	9.4	=	9.6	3M - ng/L	02/30 - Twice Per Month	CA - CALCTD
					Permit Req.		Req Mon 30DA AVG		Req Mon DAILY MX	3M - ng/L	01/30 - Monthly	CA - CALCTD
					Value NODI							

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

The laboratory used by Metro Water Recovery is able to analyze and quantify the PFAS at or below the associated PFAS QL as required per Part I. Section D.5.f of CO0026638 discharge permit. Due to the complexity of the matrix, some results for Perfluorobutanoic acid in this monitoring period were not analyzed at or below the PFAS QL. These results were included in the calculations and reported for the monitoring period.

Attachments

No attachments.

Report Last Saved By

Metro Water Recovery

User: KatieLeach
 Name: Katie Leach
 E-Mail: kkoplitz@mwr.dst.co.us
 Date/Time: 2023-01-25 15:59 (Time Zone: -07:00)

Report Last Signed By

User: jrobinett@mwr.dst.co.us
 Name: Jennifer Robinett
 E-Mail: jrobinett@mwr.dst.co.us

